

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-1591:134 Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243  
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

**DESIGN:** Models EC20FTU-3 and EC20RRU-3 two-wire heat detectors. Model EC20FTU-3 is a 135°F fixed temperature detector and Model EC20RRU-3 is a 135°F fixed temperature and a 15°F/min rate of rise detector. Refer to listee's data sheet for detailed model descriptions and operational considerations.

**RATING:** 10-30 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as 2-wire heat detectors for use with listee's separately listed compatible bases and fire alarm control units.

**NOTE:** Formerly 7270-1388:242

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**  
*Program Manager*